

Tsuu T'ina Nation Policies For

Please find attached Chief Joseph Big Plume Building policies approved by the Tsuu T'ina Nation Chief & Council
on
November 7, 2002.

**Chief Joseph Big Plume
Building**

CHIEF JOSEPH BIG PLUME BUILDING

APPROVED POLICIES (November 7, 2002)

INDEX

SECTION 1.....	BOARDROOM RENTALS.....	PAGE 1
SECTION 2.....	PARKING.....	PAGE 2
SECTION 3.....	PUBLIC NUISANCE/LOITERING/SOLICITING....	PAGE 3
SECTION 4.....	MAIN RECEPTION AREA (MAIN FLOOR).....	PAGE 3
SECTION 5.....	PARCELS (COURIERS).....	PAGE 3
SECTION 6.....	HOURS OF OPERATION.....	PAGE 4
SECTION 7.....	ENTRANCE DOORS.....	PAGE 4
SECTION 8	FRONT LAWN.....	PAGE 4
APPENDIX A	2002/2003 RENTAL FEE'S	

Please note that the following precautions are necessary for the Security and Safety of all Staff, Tenants, Governing Body and the General Public of the Chief Joseph Big Plume Building.

CHIEF JOSEPH BIG PLUME BUILDING

APPROVED POLICIES

For

SECTION 1 – BOARDROOM RENTALS

Policies applying to: Council Chambers (Veteran's Hall), All Boardrooms, Front Main Foyer, Elder's Lounge, Main Reception Areas.

1. All Council Chambers/Boardrooms/Front Main Foyer; are to be booked through the Tsuu T'ina Property Management department at Local # 103 or the main receptionist.
2. All Outside/Non-Nation Organizations must pay rental for the use of Council Chambers and Boardrooms. Any cancellations must be received 24 hours prior to the scheduled booking. Should failure to cancel booking within the said time frame, the organization will be invoiced.
3. All bookings are for meetings and workshops only. Boardrooms are not for personal use or to be used as office space.
4. The Elders Lounge will not be booked out, as this is designated for the "Elders" only. All departments are expected to respect their wishes.
5. Bookings for the Front Main Foyer (for fundraising functions) must be booked through the Tsuu Tina Property Management department at Local #103.
6. See attached Boardroom Rental list for details on rental charges for outside/Non-Nation organizations. All Audio, Video, Overhead Projector, Flipchart, etc. Equipment are not for be rent or borrow. This equipment is to stay within the premises of the Chief Joseph Big Plume Building.

SECTION 2 – PARKING

1. The Parking zone on the North and South Side of the building accommodates for all Nation Staff and tenants vehicles, as well as visitors.
2. Security will not be responsible for items stolen from vehicles parked in the parking lots. Please lock up your vehicles and your valuables. However, Security will do periodic checks of the parking lots.
3. **ABSOLUTELY NO PARKING WILL BE PERMITTED** in the:
 - a) Fire lane located in the front of the building (the ramp); and all other fire lanes;
 - b) In front of the Garbage Bins
 - c) In front of the Gates
 - d) The loading docks located on the South side and North side of the building
 - e) All other areas posted as "**NO PARKING**".
 - f) *Failure to comply will result in warning tickets that will be issued by the Tsuu Tina Police Service.*
4. **NO PARKING exceptions** will be only apply to Elders and handicap sticker users.
5. All "**Handicap Sticker Users**" must provide to the Security Personnel all documentation; this information is kept on file. Failure to provide the information will not allow you to park in designated areas.

SECTION 3 – PUBLIC NUISANCE/LOITERING/SOLICITING PROCEDURES

1. Absolutely no fighting, screaming, shouting, swearing or using insulting or obscene language in the **Chief Joseph Big Plume Building**.
2. First Offense will result in a Verbal Warning by the Security Personnel. The individual will be asked to leave the premises.
3. Second Offense will be submitted a Written Warning from the Security Personnel. The formal complaint will be referred to the Tsuu t'ina Tribal Police Services for their record.
4. Successive Offenses will be issued a **suspension letter** from the Security Personnel that he/she will be suspended from the premises for a period of one (1) month.
5. If this abusive behavior continues the individual shall be subject to criminal charges by the Tsuu t'ina Tribal Police Services.

SECTION 4 – MAIN RECEPTION AREA (MAIN FLOOR)

1. All visitors are to report to the reception front desk.
2. Absolutely no one is to enter the main floor premises unless authorized by the appropriate staff **or** Chief & Council.

SECTION 5 – PARCELS (COURIERS)

1. Security Personnel will not be responsible for the signing in and out of mail or parcels.
2. The loading docks located on the north and south side of the building are to be utilized for the delivery of large parcels/supplies.

SECTION 6 – HOURS OF OPERATION

1. Absolutely no workshops or meetings during weekends or on Statutory holidays as there will be no "Security Personnel" available on these dates.
2. No one is to be in the building after 8:00 p.m. weekdays. If a staff member must be in the building after 8:00 p.m., please notify Security. A logbook is provided for the signing in and out for staff members still in the building (after hours).

SECTION 7 – ENTRANCE DOORS

1. All visitors and non-staff members must enter the building from the Main Entrance Doors.
2. Please do no lodge objects (rugs, pens, etc.) in the doors on the north and south side of the building.

SECTION 8 – FRONT LAWN

1. There is to be absolutely no one to walk across the front lawn of the building. Everyone is to use the sidewalks to access the building.
2. If you are caught by Security Personnel, you will be given a warning.
3. All Landscaping Equipment are not for rent or borrow. Landscaping Equipment must stay on the Chief Joseph Big Plume Building premises.

**2002/2003 RENTAL CHARGE OF
BOARDROOMS/COUNCIL CHAMBERS**
Re: Outside Groups/Organizations - EFFECTIVE April 1st/02

The following is a breakdown of the rental charges (Per day) for the Boardrooms and Council Chambers:

Please Note: Full Day 8:00 a.m. - 4:00 p.m.

Half Day 8:00 a.m. - Noon or 12:00 noon - 4:00 p.m.

• Boardroom "A" (Simeon) seats approx.25 people	full day	\$275.00
	half day	\$150.00
• Boardroom "B" (Littlelight) seats approx.15 people	full day	\$275.00
	half day	\$150.00
• Boardroom "C" (Runner) seats approx 10 people	full day	\$225.00
	half day	\$125.00
• Boardroom "D" (Simon) seats approx 10 people	full day	\$225.00
	half day	\$125.00
• Boardroom "E" (Onespot) seats approx 10 people	full day	\$225.00
	half day	\$125.00
• Council Chambers (Main Floor) seats approx. 100-120 people	full day	\$400.00
	half day	\$200.00

The rental of the boardrooms includes coffee. We are not responsible for catering. The use of our photo copying services is set at .75 cents per page. The use of our facsimile machine is total number of pages sent at \$1.00 per page.

**Tsuu t'ina Property
Management
(Patricia Simon)**

emo

To: TSUU T'INA NATION
TENANTS of CHIEF JOSEPH BIG PLUME BUILDING

From: Patricia Simon, Property Management

CC: Tsuu t'ina Nation Chief & Council/Senior Management


Date: 06/28/06

Re: SMOKE FREE FACILITY

Please be advised that On June 15, 2006, a motion was passed by the Tsuu t'ina Nation Chief & Council approved the recommendation that Chief Joseph Big Plume building will be a smoke free facility. Accordingly, effective immediately, no smoking, chewing tobacco or candles, sparklers, fireworks or open flame of any kind are allowed within Chief Joseph Big Plume building, except in outside designated smoking areas, as identified in the attached schedule.

Thanking you for your cooperation.

Sincerely,


Patricia E. Simon

Tsuu t'ina Nation Property Management

DESGINATED AREAS OUTSIDE THE BUILDING:

- **MAIN DOOR:** Ashtrays will be allocated by the main front doors.
- **COUNCIL CHAMBERS:** Ashtrays will be located outside "West Side Door".
- **NORTH END LOADING DOCK:** Ashtrays will be located by the Nothh-end gate.
- **SOUTH END LOADING DOCK:** Ashtrays will be located by the South-end gate.



TSUU T'INA NATION

9911 Chiila Blvd., Tsuu T'ina (Sarcee), Alberta T2W 6H6
Telephone: (403) 281-4455 Fax: (403) 251-6061

CHIEF AND COUNCIL DIRECTIVE

TO: SENIOR MANAGEMENT
FROM: CHAIR, CHIEF SANDFORD BIG PLUME
SUBJECT: MOTION TO ACCEPT NO SMOKING RECOMMENDATIONS
DATE: THURSDAY, JUNE 15, 2006
CC: PROPERTY MANAGEMENT

At a duly convened meeting of Chief and Council held on June 14, 2006, Chief & Council approved and direct the following:

Initial discussions included striking the second sentence of the second paragraph and to include additional smoking areas to include:

1. Office of the Chief,
2. Office of the Business Development Officer,
3. Office of Councillor Regena Crowchild (Relocate Vincent Crowchild to share an office with Regena Crowchild).

However, a motion put forth by Councillor Stephen Runner to accept the "Recommendations as Presented" did not include the additional designated smoke areas as described above.

Moved by Councillor Stephen Runner and Seconded by Lyle Dodginghorse to accept the May 16, 2006 Chief Joseph Big Plume Building No Smoking Recommendations, as submitted by Patricia Simon, Property Manager.

"No Smoking, lit candles, sparklers, fireworks, or open flame of any kind are allowed within Chief Joseph Big Plume Building. Smoking is only permitted in designated areas outside the building.

During Traditional Ceremonies the smoking of traditional pipes, burning of sweetgrass and smudging shall be permitted. No other

smoking of cigarettes cigars or non-ceremonial pipes shall be permitted during Traditional Ceremonies.

DESIGNATED AREAS OUTSIDE THE BUILDING:

1. **Main Door:** THREE Ashtrays will be allocated by the main front doors
2. **Ground Floor:** TWO Ashtrays will be located by the outside door across from the teepee.
3. **Council Chambers:** TWO Ashtrays will be located outside the "West Side Door".
4. **North End Loading Dock:** TWO Ashtrays and one ashtray will be located by the gate.
5. **South End Loading Dock:** TWO Ashtrays and one ashtray will be located by the South-end gate.

Motion Carried.

Directive on Motion: The Elder's will use Chief Big Plume's office for Ceremonial use. Additionally the recommendation did not include but should have included - "Chewing Tobacco" as this is another form of Tobacco Use.

Should you have any questions and or concerns please do not hesitate to contact me.

On behalf of Chief and Council


Chair, Chief Sandford Big Plume

**TSUU T'INA PROPERTY MANAGEMENT
REVISE CHIEF JOSEPH BIG PLUME
BUILDING POLICIES**

AMENDMENTS or DELETIONS

Submitted By: Patricia Simon

***Please be advised that I have met with Nation Lawyer,
Christine Goodwin on April 29, 03 and also with Nation
Lawyer, John McDougall on April 30, 2003.**

AMENDMENTS or DELETIONS TO CHIEF JOSEPH BIG PLUME

BUILDING POLICIES

Please be advised that the following amendments or deletions are as follows;

⇒ SECTION 2 – PARKING (page 2)

Item #3: ABSOLUTELY NO PARKING WILL BE PERMITTED in the:

Delete (f) Failure to comply will result in warning tickets that will be issued by the Tsuu t'ina Police Service.

Amendment (f) The gates located on the North/South side of the building will be locked at all times.

Item #4: NO PARKING exceptions will be only apply to Elders and handicap sticker users. (add on) Tsuu t'ina Nation Elders will be issued a parking pass, if lost there will be a \$5.00 replacement fee.

⇒ SECTION 6 – HOURS OF OPERATION (page 4)

Item #1: Absolutely no workshops, meetings, or functions during weekends or on Statutory holidays without written preauthorization of Tsuu t'ina Property Management. Any authorization granted will result in the guests/employees paying the Security wages for adequate Security Personnel for the duration of the function.

Item #3: To be included: There will be no staff allowed to work on weekends, without proper authorization and notification in advance.

⇒ SECTION 9 – SMOKING (will be included):

1. No smoking, lit candles, sparklers, fireworks, or open flame of any kind are allowed within Chief Joseph Big Plume Building. Smoking is only permitted in designated areas outside the building.
2. During Traditional Ceremonies the smoking of traditional pipes, burning of sweetgrass and smudging shall be permitted. No other smoking of cigarettes, cigars or non ceremonial pipes shall be permitted during Traditional Ceremonies.

**TSUU T'INA PROPERTY MANAGEMENT
REVISE CHIEF JOSEPH BIG PLUME
BUILDING POLICIES**

AMENDMENTS or DELETIONS

Submitted By: Patricia Simon

***Please be advised that I have met with Nation Lawyer,
Christine Goodwin on April 29, 03 and also with Nation
Lawyer, John McDougall on April 30, 2003.**

AMENDMENTS or DELETIONS TO CHIEF JOSEPH BIG PLUME

BUILDING POLICIES

Please be advised that the following amendments or deletions are as follows;

⇒ SECTION 2 – PARKING (page 2)

Item #3: ABSOLUTELY NO PARKING WILL BE PERMITTED in the:

Delete (f) Failure to comply will result in warning tickets that will be issued by the Tsuu t'ina Police Service.

Amendment (f) The gates located on the North/South side of the building will be locked at all times.

Item #4: NO PARKING exceptions will be only apply to Elders and handicap sticker users. (add on) Tsuu t'ina Nation Elders will be issued a parking pass, if lost there will be a \$5.00 replacement fee.

⇒ SECTION 6 – HOURS OF OPERATION (page 4)

Item #1: Absolutely no workshops, meetings, or functions during weekends or on Statutory holidays without written preauthorization of Tsuu t'ina Property Management. Any authorization granted will result in the guests/employees paying the Security wages for adequate Security Personnel for the duration of the function.

Item #3: To be included: There will be no staff allowed to work on weekends, without proper authorization and notification in advance.

⇒ **SECTION 9 – SMOKING (will be included):**

- 1. No smoking, lit candles, sparklers, fireworks, or open flame of any kind are allowed within Chief Joseph Big Plume Building. Smoking is only permitted in designated areas outside the building.**
- 2. During Traditional Ceremonies the smoking of traditional pipes, burning of sweetgrass and smudging shall be permitted. No other smoking of cigarettes, cigars or non ceremonial pipes shall be permitted during Traditional Ceremonies.**

**Tsuu t'ina Property
Management
(Patricia Simon)**

memo

To: Tsuu t'ina Nation Departments and Companies

From: Patricia Simon, Property Management

CC: Senior Management

Date: 11/15/05

Re: CHIEF JOSEPH BIG PLUME BUILDING – Boardrooms & No Smoking Notices


Please be advised that effective November 15, 2005 all Boardrooms and Council Chambers are to be booked through Main Receptionist department at 281-4455 or receptionist local number #250 or #150.

Also, "NO SMOKING" will be implemented in the boardrooms and Council Chambers. There are smoking areas located on each floor in the hall foyers.

The "Elders Lounge" will not be booked out, as this area is designated for the "Elders" only. All departments should respect their wishes.

Thank you for cooperation and consideration to the above.

Sincerely,



Patricia Simon

Manager, Tsuu t'ina Property Management Ltd.

attachment

Memo

To: Tsuu t'ina Nation Chief & Council
From: Patricia Simon, Property Management
CC: Senior Management
Date: 06/29/06
Re: SMOKE FREE FACILITY


I would like to "commend" the leaders that supported the amendment to the Chief Joseph Big Plume building reference to a "Smoke Free Facility". It was a blessing for the non-smokers (second hand smokers) and the staff that has health issues; especially the individuals that are diagnose for asthma or emphysema.

My department received numerous telephone calls stressing to thank the Tsuu tina Nation Chief and Council for their consideration. The following Nation buildings that are "Smoke Free"; Child & Family, Spirit Healing Lodge, Adult Learning Centre, Sportsplex, High School, Chiila Elementary School, Education Office, Health Centre, Daycare Centre, Commercial Centre.

Again, thank you for making Chief Joseph Big Plume building a clean and healthy environment.

Yours truly,

Tsuu t'ina Property Management



Per: Patricia E. Simon

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA BLVD. SW

Sector: LB/TL

Date: Thursday, November 17, 2005

Zone	Location	Device	A1	TBL	Comments
Zone Name: GROUND FLOOR WEST					
01					
01	GND. FL. SW. EXIT	270SPO	OK		
Zone Name: MAIN FLOOR WEST EXIT					
02					
02	MN. FL. N. EXIT TO COUNCIL CHAMBERS	270-SPO	OK		
02	MN. FL. S. EXIT COUNCIL CHAMBERS	270-SPO	OK		
02	MN. FL. S. EXIT TO COUNCIL CHAMBERS	270-SPO	OK		
02	MN. FL. W. EXIT	270-SPO	OK		EOL
Zone Name: 2ND FLOOR WEST					
03					
03	2ND FL. S. CTR. S. STAIRS	270-SPO	OK		
03	2ND FL. W. STAIRS	270-SPO	OK		
Zone Name: NORTH ADMINISTRATION 3RD FLOOR					
04					
04	FAR SW. EXIT	270-SPO	OK		
04	SE. EXIT	270SPO	OK		
04	SW. STAIR EXIT	270SPO	OK		E.O.L.
Zone Name: GROUND FLOOR EAST					
05					
05	GND. FL. E. CTR. STAIR EXIT	270-SPO	OK		BY RECEPTION
05	GND. FL. E. STAIRS	270-SPO	OK		
05	GND. FL. SE. EXIT	270-SPO	OK		
Zone Name: MAIN FLOOR EAST EXIT					
06					
06	MN. FL. E. EXIT	270-SPO	OK		
Zone Name: 2ND FLOOR EAST					
07					
07	2ND FL. E. STAIRS	270-SPO	OK		
07	2ND FL. S. CTR. E. STAIRS	270-SPO	OK		
Zone Name: 3RD FLOOR NORTH					
08					
08	BY ELEV.	270-SPO	OK		
08	BY SE. STAIR EXIT	270-SPO	OK		
Zone Name: GROUND FLOOR LOADING DOCK					
09					
09	GND. FL. N. S. LOADING DOCK	270-SPO	OK		
09	GND. FL. NE. LOADING DOCK	270-SPO	OK		EOL
Zone Name: SOUTH STAIR #4					
10					
10	TOP OF SE STAIRS	6249	OK		
11					
11	Zone Name: SOUTH CENTRE MAIN STAIRS				

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA BLVD. SW

Detector: LB/TL

Date: Thursday, November 17, 2005

Zone	Location	Device	A1	TBL	Comments
11	TOP OF S. CTR. W. MECHANICAL STAIRS	6249		OK	
Zone Name: SOUTH STAIR #1					
12					
12	TOP OF W STAIRS	6249		OK	E.O.L.
Zone Name: ZONE# 13 SOUTH STAIR #3					
13					
13	TOP OF S. CTR. E. STAIRS	6249		OK	E.O.L.
Zone Name: ELEVATOR #1					
14					
14	TOP OF W ELEV. SHAFT	6249		OK	E.O.L.
Zone Name: ELEVATOR #2					
15					
15	TOP OF E ELEV. SHAFT	6249		OK	E.O.L.
Zone Name: ATRIUM					
16					
16	GND. FL. NW. EXIT	270-SPO		OK	
16	GROUND FLR SE EXIT	270SPO		OK	
16	GROUND FLR SW EXIT	270SPO		OK	
16	MN. FL. SE. EXIT	270-SPO		OK	
	MN. FL. SW. EXIT	270-SPO		OK	
Zone Name: WEST LOADING DOCK & GARAGE					
17					
17	W LOADING DOCK N.	270SPO		OK	E.O.L.
17	W LOADING DOCK S.	270SPO		OK	
Zone Name: MECHANICAL PENTHOUSE					
18					
18	PENT. E EXIT	270SPO		OK	E.O.L.
18	PENT. S. CTR. EXIT	270SPO		OK	
18	PENT. W EXIT	270SPO		OK	
Zone Name: MAIN FLOOR DUCT DETECTOR					
19					
19	GRND FLR ABOVE CEILING WEST CENTRE	6264-500		OK	
	OFF.				
19	SPARE				
19	WEST CENTRE OFFICE NORTH	6264-500		OK	
Zone Name: MECHANICAL ROOM GRD. FLR SOUTH					
20					
20	GRND FLR S MECH. RM	270SPO		OK	E.O.L.
Zone Name: MAIN SPRINKLER					
21					
21	GRND FLR S SPR. RM	TAMPER SW		OK	E.O.L.
	GRND FLR S SPR. RM	TAMPER SW		OK	
	GRND FLR S SPR. RM	TAMPER SW		OK	

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA BLVD. SW

Sector: LB/TL

Date: Thursday, November 17, 2005

Zone	Location	Device	A1	TBL	Comments
21	GRND FLR S SPR. RM	TAMPER SW		OK	
21	GRND FLR S SPR. RM	TAMPER SW		OK	
21	GRND FLR S SPR. RM	TAMPER SW		OK	
21	GRND FLR S SPR. RM	TAMPER SW		OK	
21	GRND FLR S SPR. RM	TAMPER SW		OK	
21	GRND FLR S SPR. RM	FLOW SW	OK		30 SECONDS WET TEST
21	GRND FLR S SPR. RM	TAMPER SW	OK	OK	
21	GRND FLR. S. SPR. RM.	FLOW SW.	OK		30 SEC. EOL

Zone Name: MAIN FLOOR NORTH ADMINISTRATION SPRINKLE

22	CHIEF & COUNCIL CHAMBERS EXIT	TAMPER	OK	
22	MN FLR S. CTR. E. STAIRWELL	FLOW SW	OK	E.O.L. 46 SECONDS WET TEST

Zone Name: NORTH ADMINISTRATION 2ND FLOOR SPRINKLER

23	S. CTR. E. STAIRWELL	FLOW SW	OK	E.O.L. 28 SECONDS WET TEST
23	S. CTR. E. STAIRWELL	TAMPER SW	OK	

Zone Name: NORTH ADMINISTRATION 3RD FLOOR SPRINKLER

24	S. CTR. E. STAIRWELL	TAMPER SW	OK	
	S. CTR. E. STAIRWELL	FLOW SW	OK	E.O.L. 31 SECONDS WET TEST

Zone Name: SOUTH OFFICE MAIN FLOOR SPRINKLER

25	S. CTR. STAIRWELL	TAMPER SW	OK	
25	S. CTR. STAIRWELL	FLOW SW	OK	E.O.L. 31 SECONDS WET TEST

Zone Name: SOUTH CENTRE WEST OFFICE - 2ND FLOOR SPR

26	S. CTR. W. STAIRWELL	FLOW SW	OK	E.O.L. 18 SECONDS WET TEST
26	S. CTR. W. STAIRWELL	TAMPER SW	OK	

Zone Name: SOUTH CENTRE EAST OFFICE - 3RD FLOOR SPR

27	S. CTR. E. STAIRWELL	TAMPER SW	OK	
27	S. CTR. E. STAIRWELL	FLOW SW	OK	E.O.L. 22 SECONDS WET TEST

Zone Name: EAST OFFICE 3RD FLOOR SPRINKLER

28	S. CTR. W. PENT. STAIRWELL	FLOW SW	OK	E.O.L. 53 SECONDS WET TEST
28	S. CTR. W. PENT. STAIRWELL	TAMPER SW	OK	

Zone Name: PENTHOUSE DUCT DETECTORS

29	PENTHOUSE MECH ROOM	6264-500	OK	BY WATER TANKS (PHOTO ELECTRIC HEAD)
29	ROOF E	1451-A	OK	E.O.L.

Zone Name: DUCT SMOKE 2ND & 3RD FLOOR

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA BLVD. SW

Inspector: LB/TL Date: Thursday, November 17, 2005

Zone	Location	Device	A1	TBL	Comments
30	ROOF W.	1451-A	OK		
30	ROOF W.	1451-A	OK		E.O.L.

Zone Name: DUCT SMOKE ATRIUM

31	ROOF E.	1451-A	OK	EOL
31	ROOF E.	1451-A	OK	

Zone Name: MAIN FLOOR COUNCIL CHAMBERS SPRINKLERS

32	S. HALL STOR. OPPOSITE EXIT	281-C	NT	CANNOT LOCATE
----	-----------------------------	-------	----	---------------

Zone Name: SOUTH SIDE MAIN FLOOR FIRE PUMP

33	FIRE PUMP	CONTACT	OK
----	-----------	---------	----

Zone Name: GROUND FLOOR SOUTH CENTRE EAST STAIRS SP

34	GND. FL. S. CTR. E. STAIRS	TAMPER	OK
----	----------------------------	--------	----

Zone Name: GROUND FLOOR FAR WEST STAIRWELL SPRINKLE

35	GND. FL. FAR W. STAIRWELL	TAMPER	OK
----	---------------------------	--------	----

Zone Name: SOUTH CENTRE GROUND FLOOR STAIRS

36	S. CTR. STAIRWELL	TAMPER	OK
----	-------------------	--------	----

Name:

37	GND. FL. E. STAIRWELL	TAMPER	OK
----	-----------------------	--------	----

Zone Name: SIGNAL CIRCUIT #1 - EAST BELLS

B1	2ND FLOOR NE LUNCH RM	439D10"	OK	HEALTH SERVICE AREA
B1	2ND FLR E OFFICE	STROBE	OK	
B1	2ND FLR E. CTR. OFFICE	STROBE	OK	HEALTH CANADA & INDIAN AFFAIRS
B1	2ND FLR EC EXIT	439D10"	OK	
B1	2ND FLR EC EXIT	STROBE	OK	
B1	2ND FLR EC MENS WASHROOM	STROBE	OK	
B1	2ND FLR EC WOMENS WASHROOM	STROBE	OK	
B1	2ND FLR S EXIT	439D10"	OK	10"
B1	2ND FLR W. CTR. OFFICE	STROBE	OK	HEALTH CANADA & INDIAN AFFAIRS
B1	3RD FL. E. EXIT	439D-10	OK	
B1	3RD FLR E HALL	STROBE	OK	
B1	3RD FLR E. CTR. EXIT	439D10"	OK	10"
B1	3RD FLR EC EXIT	STROBE	OK	
B1	3RD FLR EC HALL	STROBE	OK	
B1	3RD FLR EC LADY WSHRM	STROBE	OK	
B1	3RD FLR EC MEN WSHRM	STROBE	OK	
B1	GRND FLR CSW ELEV/MACH	439D10"	OK	10"
	GRND FLR CSW FAN RM	439D10"	OK	10" E.O.L.

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA BLVD. SW

Inspector: LB/TL

Date: Thursday, November 17, 2005

Zone	Location	Device	A1	TBL	Comments
Zone Name: SIGNAL CIRCUIT #2 - WEST BELLS					
32					
B2	2ND FLR NE HALL	STROBE	OK		
B2	2ND FLR NW HALL	STROBE	OK		
B2	2ND FLR W EXIT	STROBE	OK		
B2	2ND FLR W EXIT	439D10"	OK		10"
B2	2ND FLR WC EXIT	STROBE	OK		
B2	2ND FLR WC EXIT	439D10"	OK		10"
B2	2ND FLR WC LADY WSHRM	STROBE	OK		
B2	2ND FLR WC MEN WSHRM	STROBE	OK		
B2	2ND FLR WCE HALL	STROBE	OK		
B2	2ND FLR WCW HALL	STROBE	OK		
B2	3RD FLR W EXIT	439D10"	OK		
B2	3RD FLR W HALL	STROBE	OK		
B2	3RD FLR WC EXIT	439D10"	OK		10" E.O.L.
B2	3RD FLR WC HALL	STROBE	OK		
B2	3RD FLR WC HALL	STROBE	OK		
B2	3RD FLR WC LADY WSHRM	STROBE	OK		
B2	3RD FLR WC MEN WSHRM	STROBE	OK		
	PENT. W EXIT	439D10"	OK		10" E.O.L.
Zone Name: SIGNAL CIRCUIT #3 - COUNCIL CHAMBERS					
B3					
B3	COUNCIL CHAMBERS E LOBBY	439D10"	OK		10"
B3	COUNCIL CHAMBERS W. EXIT	439D10"	OK		10" E.O.L.
Zone Name: SIGNAL CIRCUIT #4 - COMPUTER ROOM					
B4					
B4	GRND FLR SE COMPUTER ROOM	439D10"	OK		10"
Zone Name: SIGNAL CIRCUIT #5 - WEST BUILDING					
B5					
B5	GRND FLR CNE MEN WSHRM	STROBE	OK		
B5	GRND FLR E. CTR. ENTR.	STROBE	OK		
B5	GRND FLR NE LADY RM	STROBE	OK		
B5	GRND FLR S. CTR. LOUNGE	STROBE	OK		
B5	GRND FLR W EXIT	439D10"	OK		10"
B5	GRND FLR WCE CEILING	STROBE	OK		
B5	GRND FLR WCW CEILING	STROBE	OK		
B5	GRND FLR WCW CEILING	STROBE	OK		
B5	GRND FLR WCW OFFICE	STROBE	OK		
B5	MN FLR BY E. LOADING DOCK	439D10"	OK		10" E.O.L.
B5	MN FLR CNW LADY WSHRM	STROBE	OK		
B5	MN FLR CNW MEN WSHRM	STROBE	OK		
B5	MN FLR MN. ENTR. W.	STROBE	OK		
	MN FLR NW EXIT	439D10"	OK		

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA BLVD. SW

Inspector: LB/TL

Date: Thursday, November 17, 2005

Zone	Location	Device	A1	TBL	Comments
B5	MN FLR SE ATRIUM	STROBE	OK		
B5	MN FLR SW ATRIUM	439D10"	NT		CAN'T LOCATE BURIED IN WALL
B5	MN FLR SW ATRIUM	STROBE	NT		CAN'T LOCATE BURIED IN WALL
B5	MN FLR W. CTR. EXIT	439D10"	OK		10"
B5	MN FLR W. N. C CEILING	STROBE	OK		
B5	MN FLR WCE CEILING	STROBE	OK		
B5	MN FLR WCN CEILING	STROBE	OK		
B5	MN FLR WE CEILING	STROBE	OK		

Zone Name: SIGNAL CIRCUIT #6- EAST. BUILDING

B6

B6	GRND FLR ATRIUM	439D10"	OK	10"
B6	GRND FLR E EXIT	439D10"	OK	10"
B6	GRND FLR E MECH.RM	439D10"	OK	10"
B6	GRND FLR EC EXIT	439D10"	OK	10"
B6	GRND FLR EC EXIT	STROBE	OK	
B6	GRND FLR EC LADY WSH	STROBE	OK	
B6	GRND FLR EC MEN WSHRM	STROBE	OK	
B6	GRND FLR SCE PILLAR	439D10"	OK	10"
B6	GRND FLR SE CEILING	STROBE	OK	
B6	GRND FLR SE EXIT	STROBE	OK	
B6	GRND FLR SE EXIT	439D10"	OK	10"
B6	GRND FLR SE PILLAR	439D10"	OK	10"
B6	GRND FLR SE PILLAR	439D10"	OK	10"
B6	MN FLR BY F/A PANEL	439D10"	OK	10" E.O.L.
B6	MN FLR E EXIT	439D10"	OK	10"
B6	MN FLR E. HALL	439D10"	OK	10"
B6	MN FLR LADY WSHRM CE	STROBE	OK	
B6	MN FLR MENS WSHRM CE	STROBE	OK	

A and D Number: 4912

Address Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA BLVD. SW
Inspector: BWDate: Thursday, November 17, 2005
Due Date: NOV/06

Location of Hydrant/s: MAIN ENTRANCE OF BLDG
Number of Hydrants: 1 OF 4
1. Visual Condition: GOOD
2. How many ports: 2 2.5" 1 1.5"
Make and model of Hydrant MEULLER
3. Are Hydrant caps in place? YES
4. Are Hydrant caps in good condition?
(Free of rust , obstructed threads) YES
5. Lubricate Hydrant caps? YES
6. Fully open with one or more caps removed?
- flow until water runs clearly ? YES
7. Check Hydrant for drainage.
Does Hydrant drain properly? YES
8. Does Hydrant open and close easily? YES
If no, please explain
9. Was Hydrant left in operational condition on
completion of this inspection? YES
If no, please explain

Test Information

Static Pressure 60
Residual Pressure 50
Nozzle Size - 2" Reading 25
Water Available (US Gals/Min) 594

A and D Number: 4912

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA BLVD. SW

Date: Thursday, November 17, 2005

Inspector: BW

Due Date: NOV/05

Location of Hydrant/s: NORTH OF BLDG
Number of Hydrants: 2 OF 4
1. Visual Condition: GOOD
2. How many ports: 2 2.5" 1 1.5"
Make and model of Hydrant MEULER
3. Are Hydrant caps in place? YES
4. Are Hydrant caps in good condition?
(Free of rust, obstructed threads) YES
5. Lubricate Hydrant caps? YES
6. Fully open with one or more caps removed?
- flow until water runs clearly ? YES
7. Check Hydrant for drainage.
Does Hydrant drain properly? YES
8. Does Hydrant open and close easily?
If no, please explain YES
9. Was Hydrant left in operational condition on
completion of this inspection?
If no, please explain YES

Test Information

Static Pressure 60
Residual Pressure 50
Nozzle Size - 2" Reading 25
Water Available (US Gals/Min) 594

A and D Number: 4912

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA BLVD. SW

Date: Thursday, November 17, 2005

Sector: BW

Due Date:

NOV/06

Location of Hydrant/s: SOUTH OF BLDG

Number of Hydrants: 3 OF 4

1. Visual Condition: GOOD

2. How many ports: 2 2.5" 1 1.5"

Make and model of Hydrant MEULLER

3. Are Hydrant caps in place? YES

4. Are Hydrant caps in good condition?
(Free of rust, obstructed threads) YES

5. Lubricate Hydrant caps? YES

6. Fully open with one or more caps removed?
- flow until water runs clearly ? YES7. Check Hydrant for drainage.
Does Hydrant drain properly? YES

8. Does Hydrant open and close easily? YES

If no, please explain

9. Was Hydrant left in operational condition on
completion of this inspection? YES

If no, please explain

Test Information

Static Pressure 60

Residual Pressure 50

Nozzle Size - 2" Reading 25

Water Available (US Gals/Min) 594

A and D Number: 4912

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA BLVD. SW

Date: Thursday, November 17, 2005

Inspector: BW

Due Date: NOV/05

Location of Hydrant/s: MAIN ROAD ENTRANCE TO BLDG.

Number of Hydrants: 4 OF 4

1. Visual Condition: GOOD

2. How many ports: 2 2.5" 1 1.5"

Make and model of Hydrant MUELLER

3. Are Hydrant caps in place? YES

4. Are Hydrant caps in good condition?
(Free of rust, obstructed threads) YES

5. Lubricate Hydrant caps? YES

6. Fully open with one or more caps removed?
- flow until water runs clearly? YES7. Check Hydrant for drainage.
Does Hydrant drain properly? YES

8. Does Hydrant open and close easily? YES

If no, please explain

9. Was Hydrant left in operational condition on
completion of this inspection? YES

If no, please explain

Test Information

Static Pressure 60

Residual Pressure 50

Nozzle Size - 2" Reading 30

Water Available (US Gals/Min) 651

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA Date: Thursday, November 17, 2005
 Inspector: 30 EXT.

Location	Type/Size	6YR Due	HT Due	Last HT	MFG. Date	Serial#	Comments
2ND FLR E BY WASHROOM	10LB ABC			94		5737	C
2ND FLR E OFFICE HALL E	10LB ABC			94		6256	C
2ND FLR W	10LB ABC			94		604798	C
2ND FLR W ENTRANCE	10LB ABC			94		5736	C
3RD FL. BY BARRY TYMCHUCK	10ABC			04		22988	C
3RD FLR E HALL	10LB ABC			94		6262	C
3RD FLR E SE	10LB ABC			94		5741	C
3RD FLR W ENTRANCE	10LB ABC			94		5744	C
3RD FLR W HALL	10LB ABC			94		604873	C
BANK OF MONTREAL	5LB ABC			96		107929	C
END OF HALL OUTSIDE PUMP RM	10LB ABC			94		5747	C
COMPUTER RM	5CO2			01		611327	C
GND FLR ELEC. RM	10LB ABC			94		5748	C
GND FLR FIRE PUMP RM	10LB ABC			94		5734	C
GND FLR N ELDERS LOUNGE	10LB ABC			94		6258	C
GND FLR OIL & GAS	10LB ABC			94		5745	C
GND FLR OIL & GAS E HALL	10LB ABC			94		5750	C
GND FLR RECEPTION OIL & GAS	10LB ABC			94		6257	C
GND FLR S MECH. RM	10LB ABC			94		6251	C
GRND FLR SW CORNER	10LB ABC			94		4826	C
GRND FLR WEST	10LB ABC			94		5746	C BIN 99
KITCHEN	6LTR			03		278489	C
KITCHEN-RANGE GUARD TRIM	6.0GAL			04		0	LAST SERVICE 1994
PACK							
MN FLR BY S STAIRS	10LB ABC			94		5738	C
MN FLR LOBBY	10LB ABC			94		5749	C
MN FLR N STAIRS	10LB ABC			94		604818	C

Building Tested: CHIEF JOSEPH BIG PLUME / 9911 - CHULA
Inspector: 30 EXT.

Date: Thursday, November 17, 2005

Location	Type/Size	6YR Due	HT Due	Last HT	MFG. Date	Serial#	Comments
MN FLR NC NATION	10LB ABC			94		5733	C
OIL & GAS KITCHEN	2.5LB ABC			98		4142	C
OIL & GAS S PILLAR	10LB ABC			94		5735	C
PENTHOUSE W 3RD FLR STARS	10LB ABC			94		6263	C